






Item	N/A	Done	Instruction <sup>(1)</sup>	*Ref	
1.		<input type="checkbox"/>	Openings over 24 feet wide require expansion mullions every 12 to 15 feet.	pg.3	
2.		<input type="checkbox"/>	Openings over 24 feet wide require 3/8" flashing splice joints every 12 – 15 feet. 1/4" weep holes are required at quarter points of daylight openings. See <b>Detail 3</b> .	pg.4	
3.		<input type="checkbox"/>	Horizontal glass stops should be cut to a length of daylight opening – 1/32".	pg.8	
4.		<input type="checkbox"/>	Mullion end caps must be attached and sealed to the tops of all vertical mullions and jamb mullions. See <b>Detail 15</b> .	pg.10	
5.		<input type="checkbox"/>	Profiles of horizontal, head, and sill mullions must be sealed prior to attachment to vertical mullions and jambs. See <b>Detail 17</b> .	pg.11	
6.		<input type="checkbox"/>	Flashing splices should have 3/8" space between ends. Splice sleeve should be applied with sealant and bond breaker tape. End dams should be applied and sealed. All anchors that penetrate sill flashing should be sealed. See <b>Detail 19</b> .	pg.13	
7.		<input type="checkbox"/>	Just prior to setting the frame in the flashing, a continuous bead of sealant should be applied to the top of the upturned leg on the sill flashing. All frames should be installed level, square, and true. Perimeter caulk joint width should be a minimum of 1/4" under the sill flashing and a minimum of 3/8" at the head and jambs. The fastener that attaches the sill to the flashing should not penetrate the sill flashing. All perimeter anchor heads should be sealed over.	pg.14	
8.		<input type="checkbox"/>	Water deflectors are required at the ends of all intermediate horizontals. Attach water deflectors with pre-applied tape and seal perimeter of water deflector. Seal the ramp of the water deflector to the glazing reglet walls. See <b>Detail 28</b> and <b>Detail 29</b> .	pg.19	
9.		<input type="checkbox"/>	Apply perimeter sealant at the interior and exterior of the system. Do not seal between the sill and the flashing at the exterior. Perimeter caulk bead should be under the sill flashing. See <b>Detail 31</b> .	pg.20	
10.		<input type="checkbox"/>	Apply sealant to all vertical/horizontal seams within the glass pockets. See <b>Detail 32</b> .	pg.20	
11.		<input type="checkbox"/>	Exterior glazing gaskets should be installed first. Vertical gaskets should be cut to a length of daylight opening plus 1/4" per foot of daylight opening. Horizontal gaskets should be cut to a length of daylight opening plus 1/4" per foot of daylight opening. Horizontal/vertical gasket corners should be sealed. See <b>Detail 33</b> .	pg.21	
12.		<input type="checkbox"/>	Apply sealant to the profile of the glass stops prior to installation. Detail 38. Interior vertical gaskets should be cut to a length of daylight opening plus 1/4" per foot of daylight opening. Interior horizontal gaskets should be cut to a length of daylight opening plus 1/4" per foot of daylight opening. Horizontal/vertical gasket corners should be sealed.	pg.24	

 Denotes short video clips for this step are available for viewing at [www.ykkap.com/productmaster](http://www.ykkap.com/productmaster)

(1) Please review the entire installation manual prior to fabrication and installation. This checklist is provided as a quick review during and after installation. Visit [www.ykkap.com/productmaster](http://www.ykkap.com/productmaster).

Project Name: \_\_\_\_\_